

Work Description Handout
According to D_HO_PE1

Electrical safe isolation		
Subject	Comments	Check
Obtain permit of work, execute risk assessment		
Undertake worksite preparation, tools, equipment and PPE check (having risk assessment in mind)		
Safeguard the workshop area and inform involved parties		
Use of electrical circuit drawing		
Select appropriate two-pole voltage tester, read user manual		
Carry out safe isolation of electrical circuit intended to work on		
Verification and confirmation that all electrical lines are dead		

Total time slot 45 minutes